

Appendix I

List of telecommunication room areas

Total number of pairs of recommended cable or communication volume (port)	Size of telecommunication room	Remark
Less than 200 and telecommunication room is required	2.6m ² more than 2.6m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
201~600	7m ² more than 7m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
601~1000	14m ² more than 14m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
1001~2000	20m ² more than 20m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
2001~4000	30m ² more than 30m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m

4001~6000	43m ² more than 43m ²	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m
More than 6001	Decided by telecommunication service provider, building constructor and owner of the building through negotiation	Indoor net height of at least 2.1m. The narrowest flat length should not be less than 2.5m

